

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-1193:100 Page 1 of 1

CATEGORY: Annunciators

LISTEE: Light Engineered Displays, PO Box 208, Wilmington NC 28402
Contact: Bryan Keller (910) 799-8597 Fax (910) 799-8697

DESIGN: Models LD-0, LD-1, LD-2, LD-3, *LD-4, LD-00, LD-05, LD-10, LD-20, LD-30, *LD-40, G1212, G1818, *WT-0, WT-1, WT-2, WT-3, WT-05, WT-10, WT-20, and WT-30 remote annunciators. Models FS-0, FS-1, FS-2, FS-3 and *FS-4 may also be used as Fan Status Control Station (FSCS) for smoke control equipment. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 12 - 36 VDC, 3A Max.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as remote annunciators for use with separately listed compatible fire alarm control units.

NOTE: Formerly 7300-1193:100

*Rev. 2-04-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **FEBRUARY 4, 2003**

Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**